ECOTECH

ECOTECH

World-class Air and Water Monitoring

WinAQMS

WinCollect

Ecotech Air Quality Monitoring Data Acquisition System

ECOTECH

ECOTECH

World-class Air and Water Monitoring

WinAQMS

Designed by air monitoring system people,
for air monitoring system people

www.AmericanEcotech.com

Ambient System Components

WinCollect
Data Collection &
Reporting System

Modem &
phone lines

Data Acquisition
System

Sample
Manifold

Analysers

Calibration
System

WinAQMS Datalogger “Server” = hardware + datalogging

WinAQMS Datalogger "Server" = hardware & datalogging

- Dedicated server, specifically configured solely for ambient air monitoring station use
- Windows XP PRO operating platform is pre-installed on the WinAQMS Server at the Ecotech factory
- Handles all communication between the logger and instruments, via USB, RS-232, ethernet, or analog comms.
- Supports direct digital communication from many manufacturers instrumentation
- Easily capable of storing 30 years worth of data
- Remote communication via: RS232 (PSTN, Radio etc), TCP/IP (wireless or cable network), broadband, GSM, or telephone system dial-up.

WinAQMS Datalogger "Client" = Datalogger GUI for site maintenance



WinAQMS Datalogger “Client” = GUI for site maintenance

- “Client is the graphic user interface of the WinAQMS datalogger
- Displays instantaneous and historical data in graphical and list-report type formats
- Included as part of the cost of WinAQMS datalogger
- Provides user-friendly access to settings and data
- Communicates with “WinAQMS Server" to retrieve information
- Server keeps collecting data, even if Client GUI “crashes”.
- “Remote” Client – enables one (or more) site technicians to perform remote diagnostics and maintenance
- One Remote WinAQMS Client may interrogate multiple WinAQMS dataloggers

Instantaneous Graph





- Plots instantaneous data over a user specified time period
- Ideal for the monitoring of current air quality trends
- Plot colours automatically change to indicate air quality exceedances
- Useful for viewing manual calibration sequences
- 6 data plots simultaneously
- All graph settings are user configurable

Windrose





- View current wind conditions at a glance.
- Multiple ways of viewing data readings including variable data history size, fading data and data colour changing for alarm values.

Historical Data



Re	Date/Time	C1: NO	C2: NO2	C3: NOx	C4: CO	C10:	C11: RH	C12:	C13: WS	C14: WD	C15: WS	C16: WD	C17:
1	2001/06/13 00:05:00	-6	-1	-6	0.2	16.4	100.6	895	2.1	36.1	2	37	17.4
1	2001/06/13 00:10:00	-3	-8	-11	0.2	16.4	100.4	895	2.5	50.8	2.4	27	13.4
1	2001/06/13 00:15:00	8	7	15	0.2	16.5	100.3	894	2.6	27.8	2.6	28	11.8
1	2001/06/13 00:20:00	1	6	7	0.19	16.4	100.2	894	2.8	49.5	2.7	50	17.4
1	2001/06/13 00:25:00	-2	3	1	0.19	16.4	100	894	2.5	54.4	2.4	57	14.6
1	2001/06/13 00:30:00	-1	-2	-4	0.19	16.3	100.1	894	2.2	59.1	2.1	35	16.9
1	2001/06/13 00:35:00	14	-7	7	0.2	16.3	99.7	894	2	72.9	1.8	25	25.3
1	2001/06/13 00:40:00	-5	11	6	0.19	16.4	99.4	894	1.6	98.4	1.5	15	25.9
1	2001/06/13 00:45:00	-7	2	-5	0.18	16.3	99.2	894	1.6	27.8	1.5	28	15.2
1	2001/06/13 00:50:00	-3	-3	-5	0.18	16.3	99.1	895	1.2	34.5	1.2	35	12.8
1	2001/06/13 00:55:00	-8	-4	-12	0.19	16.3	99.4	894	1.3	45	1.3	46	18.7
1	2001/06/13 01:00:00	-14	4	-10	0.19	16.2	99.6	894	1.8	52.1	1.8	52	13.9
1	2001/06/13 01:05:00	-7	6	-1	0.18	16.2	99.6	894	1.2	65.5	1.1	37	27

- Displays historical data from the database for a user selectable period
- Data automatically highlighted to represent certain "status conditions"
- Report can be one of RPT1, RPT2, RPT3, RPT4, Span, Zero, Precision or all reports

Calibration Control



- **Multipoint calibrations can be configured using a sequences made from a number of span points.**
- **Sequences can be set to run for multiple channels**
- **Point duration can be varied**
- **Analyzer state (span, zero etc) and digital outputs can be set for each point in a sequence**
- **Precision values for each channel can be set**

Calculated Channels





- Provides for creation of new channels to perform complex scalar calculations
- Supports vector averaged channels used to calculate Sigma Theta and other vector averages
- Also supports rolling averages
- Features an auto test function to ensure formula is correct

Log Book



- Allows important information to be recorded by site operators.
- Logs can be retrieved remotely.



Database

- Data stored in ASCII text format
- A new data file is automatically created each day
- Up to 4 separate data report types with individually configured averaging periods plus Span, Zero and Precision Reports
- Data can also be output to Serial port or stored in alternative data file formats.



Direct Communication



- Supports direct communication with analyzers which have ANSI terminal mode e.g. EC9800
- Enables the operator to remotely view the analyzers' configuration, status and all other information which is available through the analyzers front display
- Provides an extremely powerful station diagnostic tool

Direct Communication with GasCal



- WinAQMS now enables direct communication and configuration of the GasCal

Alarms



- May be configured to automatically send out alarm based emails.
- Can now also automatically dial up the site maintenance person in his/her office and display an on-screen alarm!

Remote Communications

- WinAQMS Client provides for remote access to a WinAQMS Server
- Select from a list of remote loggers to connect to.
- Enables a single operator to oversee multiple loggers from a remote location.



ECOTECH

ECOTECH

World-class Air and Water Monitoring

WinAQMS

Designed by air monitoring system maintenance operators, for air monitoring system maintenance operators

Ecotech WinCollect

Data Evaluation & Reporting

Software



System Configuration

Enables full remote control, data collection and generation of reports from the monitoring stations.

Requires:

- Central Windows Based PC
- WinCollect Software
- Modem or other comm

to loggers …can connect to

Ecotech WinAQMS, ESC, Campbell, Zeno, and also

connects directly to any stand alone TEOM, BAM, nephelometer, Ecotech MicroVol, Ecotech HiVol, etc

Versions

- Single User Version – install on any Windows based workstation or laptop and connect to one or many air monitoring stations
- Multiuser Version – utilizes SQL Database, enables multiple WinCollect end-users to work at same time

Data Collection

- Able to import data from a variety of Data Acquisition Systems
  - WinAQMS
  - EC9800s, M9003, MicroVol, HVS3000
  - Ecotech 9400
  - Met One E-BAM, BAM1020
  - TEOM 1400AB
  - Thermo 5400/8400N/S, Dustscan
  - Datataker
  - Opsis 600 Analyser
  - ESC loggers
- Manual import of files downloaded from:

  - Unidata loggers & Starloggers



Communication Media

WinCollect communicates through any of the following media



- PSTN phone lines
- ISDN phone lines
- GSM/CDMA
- Radio Modem
- Satellite
- TCP/IP network
- Dial-up network
- File Import - - file downloaded using “other” software and then can be manually or automatically imported
- Communication diagnostic screen

Network Configurations

Dial-up a TCP/IP network of WinAQMS effectively giving access to all loggers through one modem & phone line

- No need for modems to be connected to each loggers
- Possible to monitor multiple systems through the one phone call



Direct TCP/IP access to most supported loggers and analyzers.

Possible to view data from multiple systems simultaneously on the one WinCollect screen

Automatic Data Validation

- Data may be automatically marked invalid based on:
  - Out of tolerance concentration average
  - Out of tolerance rolling average
  - Out of tolerance span/zero calibration



Channel		Short Term Span		Long Term Span		Zero		Warning
No	Label	Warning	Invalid	Warning	Invalid	Warning	Invalid	Email Address
0	NO	3	10	5	10	3	6	richea@pandani.com
1	NO2							
2	NOx							
3	CO	3	10	5	10	0.03	0.06	richea@pandani.com
4	PM25							
5	FIL25							
6	PM10							
7	FIL10							
8	AT							
9	RH							


ECOTECH
Albedo DialUp - WinCollect
File Configure Logger View Stations Database Report Diagnostics Help
v3.2
WinCollect
ECOTECH
World-class Air & Water Monitoring
Friday, 14:58:10
Edit Channel Parameters - CCT CEM
Desc, Units, VD
Vector Pairs
Automatic Invalidation
WinCollect Alarms
WinCollect Alarms 2
AQS Settings
CH No | CH Label | Dec Pts | Units | VD Low | VDHigh | Description
0 | NO | 2 | ppm | -10 | 1000 | Nitrogen Oxide
1 | NO2 | 2 | ppm | -10 | 1000 | Nitrogen Dioxide
2 | NOx | 2 | ppm | -10 | 1000 | Oxides of Nitrogen
3 | CO | 2 | ppm | -0.1 | 100 | Carbon Monoxide
4 | PM2.5 | 1 | µg/m³ | -50 | 5000 | Particulate 2.5µm
5 | Filter25 | 0 | % | -1 | 100 | Filter 2.5µm
6 | StackTP | 1 | °C | 0 | 500 | Stack Temperature
7 | StackRH | 1 | % | 0 | 150 | Stack Humidity
8 | StackPr | 2 | atm | | | Stack Pressure
9 | StackVe | 1 | m/s | 0 | 500 | Stack Velocity
10 | H2Con | | | | | Hydrogen Leak Check
11 | 5V_ref | | V | 2.5 | 7.5 | 5V Reference
12 | 0V_ref | | V | -2.5 | 2.5 | 0V Reference
13 | 9800Span | | | | | 9800Span
14 | 9800Zero | | | | | 9800Zero
15 | Status2 | | | | | Teom 2.5 Status
16 | At_Teom | 1 | °C | 0 | 500 | AT Teom
17 | Bp_Teom | 1 | | | | BP Teom
18 | Blowback | | | | | Blowback Status
19 | RackTemp | 1 | °C | 1 | 50 | Rack Temperature
20 | MainFlow | | | | | MainFlow
21 | Aux_Flow | | | | | Aux_Flow
22 | Mode2.5 | | | | | PM2.5 Mode
23 | HCSpan | | | | | DG Control H2 Span
24 | HCZero | | | | | DG Control H2 Zero
25 | Blowbac2 | | | | | Blowback Status
26 | Cal_6 | | | | | Cal6
27 | Cal_7 | | | | | Cal7
28 | Cal_8 | | | | | Cal8
29 | PM10 | 1 | µg/m³ | -50 | 5000 | Particulate 10µm
30 | Filter1 | 0 | % | -1 | 100 | Filter 10µm
31 | Status1 | | | | | Teom 10 Status
32 | At-teom2 | 1 | °C | | | AT-Teom2.5

Automatic Data Validation

Invalid data is marked and highlighted in the database making it easy to locate.

Any manual changes made to data in the database requires the operator to enter a reason for the change.



Report	Date/Time	WS	WD	SIG	ATE	RH	BAT
0	2/02/02 06:15:00	1.5	193.		17.0	100.	12.3
0	2/02/02 06:18:00	1.4	227.		17.0	100.	12.3
0	2/02/02 06:21:00	1.9	230.		16.9	100.	12.3
0	2/02/02 06:24:00	1.3	226.		16.9	100.	12.3
0	2/02/02 06:27:00	1.1	257.		16.9	100.	12.3
0	2/02/02 06:30:00	1.8	243.		16.9	100.	12.3
0	2/02/02 06:33:00	7.7255	177.		16.9	100.	12.3
0	2/02/02 06:36:00	14.4	100.		16.9	100.	12.3
0	2/02/02 06:39:00	1.4	228.		17.0	100.	12.3
0	2/02/02 06:42:00	2.1	216.		17.0	100.	12.3
0	2/02/02 06:45:00	1.8	234.		17.0	100.	12.3
0	2/02/02 06:48:00	1.8	237.		17.0	100.	12.3
0	2/02/02 06:51:00	2.1	247.		17.0	100.	12.3
0	2/02/02 06:54:00	1.4	246.		17.0	100.	12.3
0	2/02/02 06:57:00	1.4	240.		17.0	100.	12.3

Automatic Data Validation

In the event that data downloaded is invalid an automatic email can be sent to any number of email addresses.



Automatic Report Scheduling

- Data can be automatically downloaded and reports generated automatically
- Reports can be sent to printer, screen, file, email, serial port.




WinCollect
File Edit Zoom
WIN COLLECT
ECOTECH
World-class Air & Water Monitoring
26/08/99 11:27:40
C:\Program Files\WinCollect\Collect.wsl
Station No | Site | Last Poll | Next Poll | Last Result
1 | Blackburn | 28/05/98 16:58:15 | 3/08/2010 | No answer from logger
2 | Perth | | | No answer from logger
3 | Sydney | | | No answer from logger
4 | Brisbane | 12/11/97 17:08:00 | | No answer from logger
Produce Report - AAAA test
Ecotech Demonstration
March 1998
NOx Measurement
1 day averages compiled from 10 min. data.
ppb
Date
NOx ppb
Station: Blackburn
Cancel
Communication Port Closed
Start
Microsoft PowerPoint - [Vie...
WinCollect
11:27

Report Management

Management of reports now inherits greater power, flexibility, and efficiency with the introduction of a report management interface:

- *Browse and identify report types and schedules easily*
- *Preview a reports last generated output*
- *Structure your report development*



Data Reporting Setup



Data Reporting

Reports are generated in the standard Windows Metafile format enabling them to be copied directly to other Windows applications and printed on any printer supported by Windows 2000/XP

Support for JPG, PCX, BMP, TGA and TIF graphic formats is also available for automatically generated reports

By dynamically saving reports in JPG format to a WWW server's network drive, the latest data can be made available in real-time (immediately following validation) via the internet.

Graphical Reporting

Graphs & Reports supported include:

- Line, Bar Graphs of:
  - **Average**
  - **Maximum/Minimum**
  - **Standard Deviations**
  - **Rolling Averages**
  - **Percentile**
  - **Log Mean**
- Diurnal Graphs
- Average Pollution Plots
- Percentage Pollution Concentrations
- Scatter Plots with linear regression
- Frequency Distribution Histograms
- Cumulative Frequency Distribution Plots
- Wind Rose Polar Pollution, Polar Scatter Plots
- List reports



Scatter Plot

Graphical Reports



Pollution Index



Pollution Rose


Report Specification
Report Name
R&D-Pollution Index
Report Format
Pollution Index
Station No.
6 : R&D WinAQMS
Report Type
RPT2
Channel
1 : Temp
Report Heading
Pollution Index at Blackbu
Start Date/Time
1/02/02
End Date/Time
15/02/02
Time Format
ddd dd/mm/yy to
Averaging Period
0:01:00
Percentile
75
Parameter (Average, Max, GM)
Average
Breakpoint 1
34
Breakpoint 2
67
Breakpoint 3
100
Breakpoint 4
150
Breakpoint 5
0
Breakpoint 6
0
Breakpoint 7
0
Breakpoint 8
0
Breakpoint 9
0
Breakpoint 10
0
Minimum Value
0
Maximum Value
200
Minimum Data %
75
Alternative Units
Stations
1 : PAC MELBOURNE
2 : Transurban - Grant St
3 : Transurban - Madden Gr
4 : ACI Glass
5 : Domain Stack - Opsis
6 : R&D WinAQMS
Channels
Scale
11 : WD
12 : Sigma
13 : RTemp
CC 1 : PI_SO2
CC 2 : PI_NO2
CC 3 : PI_CO
Produce Report
Set Level Markers
Set Colours
Save
Ok
Cancel
Set Graph Colours
Trace
<34
Very Good
<67
Good
<100
Fair
<150
Poor
>=150
Very Poor
Ok
Cancel


Report Specification
Report Name
Polar Scatter Plot
Report Format
Polar Plot (Scattered)
Station No.
1 : BLACKBURN
Report Type
RPT2
Channel
7 : PM1
Report Heading
This is a Polar Scatter Plo
Breakpoint 1
0
Breakpoint 2
25
Start Date/Time
1/12/97
End Date/Time
1/01/98
Time Format
Wind Direction Channel
16 : WD1
Window Start
00:00
Wind Speed Channel
15 : WS1
Window End
24:00
Number of Compass Points
24
Produce Report
Close
Cancel

Windrose Graph




WinCollect - [Produce Report - AAAA test]
File Edit Zoom
Ecotech Demonstration
March 1998
NOx & PM10 Measurement day averages compiled from 10 min. data.
100
90
80
70
60
50
40
30
20
10
0
1
8
15
22
29
Date
NOx ppb
Station: Blackburn
PM10 Particles µg/m³
Station: Blackburn
NOx ppb
Station: Perth
PM10 Particles µg/m³
Station: Perth
Communication Port Closed
Start
Microsoft PowerPoint
WinCollect - [Produ...
13:53



BLACKBURN

Ambient Air Monitoring Station

Date - Time	Ambient Temperature (°C)	Room Temperature (°C)	Rack Temperature (°C)	Relative Humidity (%)	Room RH (%)	Wind Speed (m/s)	Wind Direction	Sigma Theta
14 Feb 2002 - 11:00	35.3	23.4	29.8	33	44	3.6	NNE	30
14 Feb 2002 - 12:00	37.5	23.8	30.2	30	44	3.3	NNE	34
14 Feb 2002 - 13:00	39.2	24.4	30.7	27	44	2.6	N	39
14 Feb 2002 - 14:00	39.9	25.1	31.4	25	43	1.8	NNW	46
14 Feb 2002 - 15:00	40.4	25.6	32.1	21	42	1.3	NW	45
14 Feb 2002 - 16:00	41.0	26.1	32.5	19	41	1.8	N	42
14 Feb 2002 - 17:00	40.2	26.3	32.8	20	40	1.1	NW	45
14 Feb 2002 - 18:00	38.9	25.9	32.6	23	38	1.4	NNW	35
14 Feb 2002 - 19:00	38.0	25.7	32.5	26	37	1.9	NNE	19
14 Feb 2002 - 20:00	35.2	25.4	32.2	31	38	0.7	NE	14
14 Feb 2002 - 21:00	33.2	24.9	31.8	35	38	1.7	ENE	14
14 Feb 2002 - 22:00	32.6	24.5	31.4	35	39	2.2	ENE	15
14 Feb 2002 - 23:00	31.2	24.1	31.0	38	39	2.2	NE	15
15 Feb 2002 - 00:00	30.2	23.7	30.6	40	39	2.6	NE	13
15 Feb 2002 - 01:00	29.3	23.2	30.2	42	39	3.3	NE	11
15 Feb 2002 - 02:00	28.5	22.8	29.9	44	39	2.1	NE	11
15 Feb 2002 - 03:00	27.9	23.0	29.9	45	42	2.2	NE	12
15 Feb 2002 - 04:00	28.7	23.0	30.1	41	42	3.1	NE	13
15 Feb 2002 - 05:00	29.1	23.1	30.1	39	42	3.7	NE	12
15 Feb 2002 - 06:00	28.8	23.1	30.1	42	41	2.9	NNE	14
15 Feb 2002 - 07:00	29.5	23.3	30.1	43	42	3.5	NE	15
15 Feb 2002 - 08:00	31.6	23.2	30.0	40	42	3.8	NNE	19
15 Feb 2002 - 09:00	33.9	23.0	29.8	38	42	4.6	NNE	25
15 Feb 2002 - 10:00	35.6	23.4	30.0	35	43	4.6	NNE	31

This is not validated data!

Home

List Reports

List reports easy and quick to design & modify

- **List Report Wizard**
  - Helps design first report
  - Step by step directions
- **Easier to move/copy list report components**
- **Grid added improving navigation**




WinCollect - [Edit List Report]
File Edit Settings Zoom Help
Daily Summary Report
Invalid Time Period
Time
Ch : 0
Ch : 1
Ch : 4
Ch : 5
Ch : 6
Ch : 8
Ch : 9
Ch : 10
Ch : 11
Ch : 12
Ch : 13
VAR1
Average
Capture
Precision
Span
Zero
Object
Block
Report
Object 8 - VAR8 (Data)
Class
Data Variable
Type
Vector Average WD
Format
####0.0
Station
6 : R&D WinAQMS
Channel
9 : RoomRH
Data
RPT1
View data import conditions?
No
Font
Arial in 10 point
Alignment
3- Center
Label
VAR8
Top
-0.01 mm
Left
122.01 mm
Height
7.00 mm
Width
13.60 mm
All Communication Ports Closed

List Reports - Web

- Can dump list reports straight to an ASCII file
- This enables both text files and HTML files to be generated
- This then enables the HTML file to be automatically transferred to a web site at a pre-set interval
- "Undo" feature added for list report editor



BLACKBURN

Ambient Air Monitoring Station

Date - Time	Ambient Temperature (°C)	Room Temperature (°C)	Deck Temperature (°C)	Relative Humidity (%)	Room RH (%)	Wind Speed (m/s)	Wind Direction	Sigma Theta
14 Feb 2002 - 11:00	35.3	23.4	29.8	33	44	3.6	NNE	30
14 Feb 2002 - 12:00	37.3	23.8	30.2	30	44	3.3	NNE	34
14 Feb 2002 - 13:00	39.2	24.4	30.7	27	44	2.6	N	39
14 Feb 2002 - 14:00	39.9	23.1	31.4	25	43	1.8	NNW	46
14 Feb 2002 - 15:00	40.4	23.6	33.1	21	42	1.3	NW	45
14 Feb 2002 - 16:00	41.0	24.1	32.5	19	41	1.8	N	42
14 Feb 2002 - 17:00	40.2	24.3	32.8	20	40	1.1	NW	45
14 Feb 2002 - 18:00	38.9	23.9	32.6	23	38	1.4	NNW	33
14 Feb 2002 - 19:00	38.0	23.7	32.5	26	37	1.9	NNE	19
14 Feb 2002 - 20:00	36.2	23.4	32.2	31	38	0.7	NE	14
14 Feb 2002 - 21:00	33.2	24.9	31.8	33	38	1.7	ENE	14
14 Feb 2002 - 22:00	32.6	24.5	31.4	33	39	2.2	ENE	13
14 Feb 2002 - 23:00	31.2	24.1	31.0	38	39	2.2	NE	13
15 Feb 2002 - 00:00	30.2	23.7	30.6	40	39	2.6	NE	13
15 Feb 2002 - 01:00	29.3	23.2	30.2	42	39	3.3	NE	11
15 Feb 2002 - 02:00	28.3	22.8	29.9	44	39	2.1	NE	11
15 Feb 2002 - 03:00	27.9	23.0	29.9	43	42	2.2	NE	12
15 Feb 2002 - 04:00	28.7	23.0	30.1	41	42	3.1	NE	13
15 Feb 2002 - 05:00	29.1	23.1	30.1	39	42	3.7	NE	12
15 Feb 2002 - 06:00	28.8	23.1	30.1	42	41	2.9	NNE	14
15 Feb 2002 - 07:00	29.3	23.3	30.1	43	42	3.5	NE	13
15 Feb 2002 - 08:00	30.6	23.2	30.0	40	42	3.8	NNE	19
15 Feb 2002 - 09:00	33.9	23.0	29.8	38	42	4.6	NNE	23
15 Feb 2002 - 10:00	35.6	23.4	30.0	33	43	4.6	NNE	31

This is not validated data!

Other Improvements

- Can reboot ESC, 9400 and WinAQMS loggers
- Can re-generate “auto-generation” reports on-demand
- Can monitor multiple stations simultaneous on one screen useful when running monitoring network




WinCollect
ECOTECH

Ecotech WinAQMS
+
Ecotech WinCollect

= a comprehensive data acquisition, maintenance, validation, and reporting system designed by air monitoring maintenance operators & data validators.